



NSF/ANSI STANDARD 61

Drinking Water System Components - Health Effects

Bermad CS Ltd

Kibbutz, Evron 25235

Israel

972-4-9855311 972-4-9855311

Facility : Kibbutz, Evron, Israel

Mechanical Devices - Valves

Trade Designation	Size	Water Contact Temp	Water Contact Material
700 Series Control Valves[1] [G]	1 1/2" - 32"	CLD 23	MLTPL

[1] 700 Series Control Valves are Certified to be used with Listed control trim (pilots, fittings and tubes). The following accessories are Certified for use with valves 1 1/2" - 32". The accessories range in size from 1/8" - 1/2" diameter.

*Male Connector 768L
Hex, Nipple 122H
Male Elbow 769L
Elbow 100H
Male Branch Tee 772L
Branch Tee 3600H
Tube
Pilot BP
Pilot PA
Pilot HC
Self Flushing Filter
Y-Filter Y10
Check Valve H410 SS
Cock Valve S20
Needle Valve V6 and V8 Series
Hydraulic Relay (Amplifier)*

[G] Product also Certified to NSF/ANSI 61, Annex G and is in compliance with California's Health & Safety Code Section 116875 (commonly known as AB1953) and Vermont Act 193. Weighted average lead content <=0.25%; Solder and flux lead content <=0.2%.
